

Epoxy Testing

for

Kretus, Inc.

OMG Blocker

Kretus, Inc. 1055 W. Struck Ave. Orange, CA 92867

April 14, 2025

717 INDUSTRIAL DRIVE | ELMHURST, ILLINOIS 60126 USA | PHONE: (630) 501-0230 WWW.NELSONTESTING.COM



April 14, 2025

Kretus, Inc. 1055 W. Struck Ave. Orange, CA 92867

REPORT OF TESTS

SUBJECT:	Physical Analysis of Epoxy
PROJECT:	Kretus – OMG Blocker
TEST METHOD:	ASTM E96, "Standard Test Methods for Water Vapor Transmission of Materials"
MATERIAL:	Received by NTL on January 27, 2025
NTL PROJECT #:	25-1032
PAGE:	1 of 3

TEST DATA

Material:	OMG Blocker
Batch #:	Batch #2405-0053 and Batch #2407-0036
Curing:	48 hour air cure before testing



April 14, 2025 Kretus – OMG Blocker NTL Project #25-1032 Page 2 of 3

TEST RESULTS

ASTM E96 – Water Vapor Transmission

Material:	OMG Blocker
Application:	16 mils
Cast Date:	February 2025
Start Date:	March 2025
Test Duration:	21 days
Parameters:	Procedure B (water method at 50% RH, 73 deg F.)
Specimens:	Coated concrete specimens (3 x 6 x 1.0-in)

Results:

Water Vapor Permeance (perms)

AVERAGE	0.059 perms (grains/h-ft²-in Hg.)
Specimen 3	0.052 perms (grains/h-ft²-in Hg.)
Specimen 1	0.055 perms (grains/h-ft²-in Hg.) 0.070 perms (grains/h-ft²-in Hg.)
o · · ·	

PICTURE (during testing)



717 INDUSTRIAL DRIVE | ELMHURST, ILLINOIS 60126 USA | PHONE: (630) 501-0230 WWW.NELSONTESTING.COM



April 14, 2025 Kretus – OMG Blocker NTL Project #25-1032 Page 3 of 3

Respectfully submitted,

NELSON TESTING LABORATORIES

Mark R. Nelson President

<u>Notes</u>: The results listed within this report relate only to the materials submitted for testing. This report shall not be reproduced, except in full, without written approval of this laboratory. The test materials not consumed in this testing will be discarded 14 days from the date of this report unless we receive written notification requesting otherwise. When applicable, Nelson Testing Laboratories uses the simple acceptance/simple rejection decision rule to determine in-tolerance and out-of-tolerance conditions and no measurement uncertainty was applied in that determination.

Accreditation and Certification listings for Nelson Testing Laboratories are located at www.nelsontesting.com.

*Report updated on April 14, 2025 to update the company name and product name.